

Certificate of Compliance



Yadav Measurements

YADAV MEASUREMENTS PVT. LTD.

Plot no.373-375, RIICO Bhamashah Industrial Area
Kaladwas, Udaipur-313003 India

Email : yadav.measurements@ymllabs.com
Website: www.yadavmeasurements.com

Certificate Number : COC / 2018-2019 / 04 Dated: 18/06/2018

Tests

Accuracy Test : Active energy class 1.0 and reactive energy class 2.0 as per
EN/ IEC 62052-11, EN/ IEC 62053-21:2003 Amend 1 and
EN /IEC 62053-23: 2003 + Amend 1 clause 8.1 (table 6 & 7)

Voltage Variation Test : EN/ IEC 62053-21:2003 Amend 1 clause 8.2

Frequency Variation Test : EN/ IEC 62053-21:2003 Amend 1 & clause 8.2

Report reference : UKAS accredited certificate no.
YMPL/2018-2019/215/1/19 & YMPL/2018-2019/215/3/20

Issue date : 16-June-2018

Issued to : SOCOMEC S.A.S 1 RUE DE WESTHOUSE,
67235, BENFELD CEDEX, FRANCE

This is to certify that representative samples of :

3 Phase, 4 Wire, ac static energy meter, type: **COUNTIS E23 & COUNTIS E24**, current rating 5-80A,
3X230 (400) VAC to 3X240 (415) VAC, 50Hz, Accuracy class: 1.0

have been tested by Yadav Measurements Private Limited in accordance with the standard(s)
indicated on this certificate for tests mentioned above. This is to certify that the specimen is/are in
conformity with the requirements of the standards as mentioned above.

Additional Information: Nil

UMESH SONI
(Manager)