



Ref. Certif. No.

CN55103

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

SWITCH DISCONNECTOR FUSE

Name and address of the applicant

SOCOMEC S.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMEC S.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMEC S.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 8kV;Ui: 800V;Ith: 20A(FUSERBLOC CD 20A),32A(FUSERBLOC CD 32A);Ue: AC690V;Ie: 20A(FUSERBLOC CD 20A),32A(FUSERBLOC CD 32A); Utilization category: AC-23A;Number of poles:3P,4P;Iq: 80kA;Rated frequency :50/60Hz

Trademark / Brand (if any)

SOCOMEC

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FUSERBLOC CD 20A,FUSERBLOC CD 32A;

Additional information (if necessary may also be reported on page 2)

IEC 60947-1:2020;IEC 60947-3:2020

A sample of the product was tested and found to be in conformity with

00901-CB2021CQC-099772

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.09,2021

Signature:

谢肇旭

Xie ZhaoXu



CB 0065323