

**IEC****IECEE**

TM

Ref. Certif. No.

CN55582-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

SWITCH DISCONNECTOR

Name and address of the applicant

SOCOMECS.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Socomec Co.,Ltd.  
(Zhejiang KEDU Electric Manufacture Co.,Ltd.) Heshenqiao Industrial Zone, Puqi Town, Yueqing, Zhejiang Province, P.R.China

Ratings and principal characteristics

 Additional information on page 2

Uimp: 8kV;Ui: 800V;Ith: 63A, 80A,100A;Ue: AC415V;Ie: 63A, 80A,100A; Utilization category: AC-23A(63A,80A);AC-22A(100A); Number of poles:3P, 4P(with additional pole); Icw: 1.5kA/1s;Icm(Peak value): 2.1kARated frequency :50/60Hz

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO M63, SIRCO M80,SIRCO M CD100;

Additional information (if necessary may also be reported on page 2)

IEC 60947-1:2020;IEC 60947-3:2020

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-099881-A1

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: Jan.04,2022

Signature:

谢肇煦

Xie ZhaoXu

**CB 0066302**

**IEC****IECEE**

®

TM

Ref. Certif. No.

CN55582-A1

Name of the factory	Address of the factory
1.SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia

Additional information (if necessary)

Date: Jan.04,2022

Signature:



Xie ZhaoXu